LABORATORY PUBLIC HEALTH ENGINEERING DEPARTMENT

MAINTENANCE SUB DIVISION NO. 2, P.H.E. DEPTT., UJJAIN

Sample from : Akshat In

Akshat International School, Lalpur, Ujjain

Particular of sample

Sample No. 1) Well Water

Date of collection

02-01-23

Date of Analyisis

02-01-23

S. NO.	Characteristics	Unit	Appendex-23 (a) As per manual on water supply Treatment prepared published by CPHEEO-MANUAL		Result Well Water					
			Acceptable	Cause for rejection	1	2	3	4	5	
	Physical							3		
1.	Turbidity	NTU	2.5	10.0	0.6			23		
2.	Colour	PICobalt	5.0	25.0	NIL	*			F	
		Scale			2					
3.	Taste and odour	-	Unobjectionable	Unobjectionable	NIL		5			
	Chemical									
4.	PH	PH	7.0 to 8.5	<6.5 to 9.2>	8.1			1		
		Scale							8	*
5.	Total Alkalinity	Mg/1	200	600	080			j.		
6.	Chloride	-	Up to 200	1000	110					
7.	Total Hardness	Mg/1	200as CaCO3	600as CaCO3	118					
8.	Calcium Hardness	-								* .
9.	Magnesium Hard.	-								
10.	Total Dissolved	_	500	2000	191	/				
	Solid						_			
11.	Iron	Mg/1	0.1	1.0	NIL					
12.	Fluoride	-	1.0	1.5	0.2		e:			
13.	Maganese	-	0.3	1.0	_					
14.	Dissolved oxygen	_	-	_	_			7,		
15.	C.O.D.	_	10		_			1 72 T		
16.	B.O.D	_	06	- ·	_			, ,		
17.	Residual chlorine	-	02	1.0	NIL					
18.	Coagulant dose	_			-					
10.	at test						'V 11 W			
	at test	,								
									*	
								2		1

NOTE: 1. The figure indicated under the columnacceptable are the limits upto which the water is generally acceptable to the consumers.

2. Figure in excess of those mentioned under acceptable render the water not acceptable but still tolerated in the absence of alternative and better source but upto the limits indicated under column 'cause for rejection' above which the supply will have to be rejected.

Bacteriological (M. P. N.) of co	oli form per 100 ml of sample – 1) N	NIL CONTRACTOR OF THE PROPERTY
Special Test		
(1)		
(2)		*
(3)		
Chemist :		
Remarks: All the tested para	meter results are under limits as per	r CPHEEO manual.
So, water can be u	sed for the drinking purpose.	
		8
	1	Thosa .
		Chemist Laboratory Incharge
		FILTRATION PLANT
		GAU GHAT, UJJAIN
Note:		
	etad by consumar	
East: Water sample is collect		PEDVICE
U	ON INDIA GOVERNMENT S	DERVICE
	то,	STAMP
No	Akshat International School	
	Lalpur	
	Ujjain (M.P.)	